

Table 2 Residual chlorine (WHO guide value: > 0.2 mg–0.5 mg/l) and turbidity (WHO guide value: < 5 nephelometric turbidity unit)

Town	Phase 1 Onset of emergency			Phase 2 Emergency response			Phase 3 Post-emergency		
	Residual chlorine		Turbidity	Residual chlorine		Turbidity	Residual chlorine		Turbidity
	No. of tests	% matching WHO guide value	% matching WHO guide value	No. of tests	% matching WHO guide value	% matching WHO guide value	No. of tests	% matching WHO guide value	% matching WHO guide value
Muzaffarabad	40	60	95	174	85	99	320	80	98
Bagh	26	0	90	112	77	98	280	12	94
Rawalakot	25	0	75	96	71	97	190	3	78
Mansehra	26	0	80	102	78	98	178	15	86
Battagram	25	0	78	86	70	89	170	02	86