

Table 3 Average Legionella spp. counts 4 days post biocide treatment for the old technology cooling tower units, Qatar University campus, 2013-2014

Cooling tower no.	Average monthly CFU/mL
1	25.3
2	62.8
3	33.2
4	32.7
5	69.3
6	16.5
7	24.6

CFU = colony-forming units.